



Nevada Board for the Regulation of Liquefied Petroleum Gas
Post Office Box 338 • Carson City, Nevada 89702
Phone: (775) 687-4890 • Fax: (775) 687-3956
Web Site: www.lpg.nv.gov

Type 2A COC EXAM INFORMATION

Section 1

Reference books allowed to be used:

None

Main areas of knowledge to be tested:

Properties of LP-Gas
Storage of cylinders
Cylinder appurtenances

Number of questions:

Minimum of 25

Sample test questions:

Sample Question 1

How many BTU's per pound of propane liquid? _____

Sample Question 2

LP-Gas in its natural state is odorless:

- A) True
- B) False

Sample Question 3

A DOT Cylinder not equipped with a fixed liquid level gauge must be filled by:

- A) Volume
- B) Gallons
- C) Liters
- D) Weight

Section 2

Reference books allowed to be used:

All reference books are allowed, however, the exam is primarily based on the following:

NFPA 58 (2004)

(The board does NOT provide reference books)

Main areas of knowledge to be tested:

Cylinder installation, cylinder appurtenance installation and repair, cylinder transportation.

Number of questions:

Minimum of 25

Sample test questions:

Sample Question 4

Cylinder valves must be protected from damage by:

- A) Ventilated collar
- B) Ventilated cap
- C) Either A or B
- D) None of the above

Sample Question 5

What is the maximum size (water capacity) cylinder that can be stored within a building frequented by the public?

- A) 20 lb.
- B) 2.7 lb.
- C) 30 lb.
- D) 1.5 lb.

Sample Question 6

Cylinders and their appurtenances shall be determined to be leak free before being loaded into vehicles:

- A) True
- B) False

QUALIFIED PERSON (QP) ENDORSEMENT

All persons who will be designated as the qualified person for the licensee will also be required to successfully complete the QP exam.

Reference books allowed to be used:

All reference books are allowed, however, the exam is based on the following:

NRS 590.465 to 590.645 and NAC 590.100 to 590.687

(The board WILL provide reference books at the exam or they can be viewed from the Boards web site prior to the exam)

Main areas of knowledge to be tested:

Nevada statutes and regulations regarding LP-Gas

Number of questions:

Minimum of 25

Sample test questions:

Sample Question 7

If you are a business engaged in the sale, transportation and exchange of cylinders, but not in transporting or transferring gas in liquid bulk; then what general class of license is required from the Board?

- A) Class 1
- B) Class 2
- C) Class 3
- D) Class 4

Sample Question 8

Licensed firms must have insurance against liability for injury to persons and damage to property.

- A) True
- B) False

HELPFUL INFORMATION

Approximate Properties of LP-Gases	Commercial Propane
Vapor pressure in psi (absolute pressure) at	
70° F	145
100° F	218
105° F	233
130° F	315
Specific gravity of liquid (water = 1) at 60° F	0.504
Initial boiling point at 14.7 psia, °F	-44
Weight per gallon of liquid at 60° F, lb	4.20
Specific heat of liquid, Btu/lb at 60° F	0.630
Cubic feet of vapor per gallon at 60° F	36.38
Cubic feet of vapor per pound at 60° F	8.66
Specific gravity of vapor (air = 1) at 60° F	1.50
Ignition temperature in air, ° F	920 - 1120
Maximum flame temperature in air, ° F	3595
Limits of flammability in air, percent of vapor in air-gas mixture	
Lower	2.15
Upper	9.60
Latent heat of vaporization at boiling point	
BTU per pound	184
BTU per gallon	773
Total heating values after vaporization	
BTU per cubic foot	2,488
BTU per pound	21,548
BTU per gallon	91,502

Answers to sample exam questions:

- 1) 21,548 [NFPA 58 (2004) Table B.1.2 (a)]
- 2) A [Industry knowledge]
- 3) D [NFPA 58 (2004) 7.4.3.1]
- 4) C [NFPA 58 (2004) 8.2.2.1]
- 5) B [NFPA 58 (2004) 8.3.2.2]
- 6) A [NFPA 58 (2004) 9.3.2.6]
- 7) B [NRS 590.575]
- 8) A [NAC 590.270]